



Certificate of Compliance

This certificate is issued for the following:

MASTER STREAM NOZZLES FOR USE WITH MONITORS

Nozzle	Type	Material	Pressure psi (bar)	Flow gpm (Lpm)	Pattern Control	Inlet (NHT)
IMS-500	Constant Gallorage	Brass	100 (6.9)	500 (1893)	Manual	2.5"(64 mm)
CJN-B	Constant Gallorage	Brass	100 (6.9)	750 (2839) 1000 (3785)	Manual	2.5"(64 mm)
CJN-B-RC	Constant Gallorage	Brass	100 (6.9)	750 (2839) 1000 (3785)	Remote	2.5"(64 mm)

Prepared for:

Elkhart Brass Mfg. Co., Inc.
1302 West Beardsley Avenue
Elkhart, IN 46515

FM Approvals Class: 5511

Approval Identification: 3038493

Approval Granted: January 28, 2011

Said Approval is subject to satisfactory field performance, continuing follow-up Facilities and Procedures Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

For more than 160 years FM Approvals has partnered with business and industry to reduce property losses.



Member of the FM Global Group

Richard B. Dunne
Group Manager - Hydraulics
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062

January 28, 2011