



# Certificate of Compliance

This certificate is issued for the following:

## **Angle Hose Valves**

### **Model U30**

(see detailed listing attached)

## **Pressure Reducing Angle Hose Valves**

### **Model UP30 and UP35**

(see detailed listing attached)

### **Prepared for:**

Elkhart Brass Mfg Co Inc  
Box 1127  
1302 West Beardsley Ave  
Elkhart, Indiana 46515  
USA

FM Approvals Class: 1521 (December 2014)

Approval Identification: PR454669  
Superseded by: RR227188

Approval Granted: September 23, 2019  
Date Approved: March 2, 2021

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read "D. B. Fuller".

---

David B. Fuller  
VP, Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062



*Member of the FM Global Group*



# Certificate of Compliance

## Model U30

Model No	Description	Valve Size		Rated Working Pressure	
		in	(mm)	psi	(kPa)
U30	Standard Hose Valve Female NPT x Male NH, Female NPT x Female NPT	1 1/2	(38)	300	(2065)
U30	Standard Hose Valve Female NPT x Male NH Female NPT x Female NPT	2 1/2	(64)	300	(2065)

## Model UP30 and UP35

Model No	Description	Valve Size		Rated Working Pressure	
		in	(mm)	psi	(kPa)
UP30	Pressure Restricting Hose Valve Female NPT x Male NH Female NPT x Female NPT	1 1/2	(38)	175	(1205)
UP30	Pressure Restricting Hose Valve Female NPT x Male NH Female NPT x Female NPT	1 1/2	(38)	300	(2065)
UP35	Pressure Restricting Hose Valve Female NPT x Male NH Female NPT x Female NPT Rc x M78x2	2 1/2	(64)	175	(1205)
UP35	Pressure Restricting Hose Valve Female NPT x Male NH Female NPT x Female NPT Rc x M78x2	2 1/2	(64)	300	(2065)

